



Inspection Report

JUNGLE ADVENTURES INC

Customer ID: **3094**

Certificate: **58-C-1048**

Site: 001

JUNGLE ADVENTURES INC

26205 E COLONIAL DR

Type: ROUTINE INSPECTION

CHRISTMAS, FL 32709

Date: 10 April 2014

3.84

CLEANING, SANITIZATION, HOUSEKEEPING, AND PEST CONTROL.

There is a small area in the roof above the primate dens where the plywood is wet, deteriorated, and has a hole due to rain seepage. This roof shall be repaired or replaced so that this wet, deteriorated, area does not get any larger; which can contribute to mold, mildew, and fungal growths. These types of growths can affect the air quality in this area, which can cause respiratory irritations or diseases to the primates when they are in their dens.

Correct by May 10, 2014

3.127 (d)

FACILITIES, OUTDOOR.

The perimeter fence located at the entrance of the facility has been changed and is now 7 feet high. The perimeter fence shall be at least 8 feet high for facilities that house dangerous mammals.

Correct by May 10, 2014

The inspection & exit interview was conducted with the Animal Care & Medical Manger and the Asst. Animal Care & Medical Manager.

Prepared By:

ROBERT BRANDES, D V M

ROBERT BRANDES, D V M USDA, APHIS, Animal Care

Date:

Title:

VETERINARY MEDICAL OFFICER Inspector 2002

10 April 2014

Received By:

(b)(6), (b)(7)(c)

Date:

Title:

10 April 2014